



OFFICE OF DEPUTY CHIEF EXECUTIVE

OFFICER

Patient Centered Care

Date: October 29th, 2024

ADDENDUM I TO THE TENDER FOR SUPPLY OF AIR COMPRESSOR AND VACUUM PUMP AT KFHR

Reference is made to the tender No. 08 /G/NCB/2024-2025/KFHR related to the supply and installation of air compressor and vacuum pump at King Faisal Hospital Rwanda (KFH-R), advertised in Job in Rwanda on October 11th, 2024, which was scheduled to be opened on November 1st, 2024.

This serves to inform you that there are some changes in technical specifications as indicated below:

ITEM No.	QTY	Unit	Item
1	1	PC	AIR COMPRESSOR rotary screw compressor 1.20m ³ /min @ 7.5 bar(g) working pressure, maximum pressure 8 bar(g), 7.5 kW motor - dryers TBH16, 2.2m ³ /min
2	1	PC	DRYER - max pressure : 16bar - power : 3 phase, 400V , 5.6A, 50HZ - refrigerant: R513 - flow 15,5 m ³ /min
3	1	PC	VACUUM PLANT Capacity: 1000LPM*2 Max. Pressure: 0.1mbar Power Consumption: 2.2KW*2 Size: 1200*850*1560(mm) Weight: 475KG Noise Level: ≤ 62dB(A) Flow 2*40m ³ /h

The deadline for submission is extended to November 8, 2024

Note: The submission, opening time and other conditions remain unchanged

Mr. Frederic NGIRABACU
Deputy Chief Executive Officer, KFHR

